




## FIRE LANE

Fire lanes shall be marked by a six-inch (6") stripe using red traffic paint and should state "**FIRE LANE NO PARKING**" and "**TOW AWAY ZONE**" painted on the stripe at intervals of twenty-five feet (25'). The lettering shall be four inches (4") in height with a one-inch (1") wide stroke painted in white traffic paint. Minimum width of a fire lane is twenty feet (20').



Fire lane markings may, where appropriate or mandated, be placed on a concrete curb and will conform to the above outlined scheme. In those places of less than twenty-five foot (25') distance, the spacing may be altered to accommodate the wording as required.

Fire lane locations: Fire Department access turnarounds, in front of FDC's (sprinkler or standpipe connections), in and around exit discharge areas, in and around fire hydrant locations and/or other locations as determined by the Fire Marshal's Office.

Fire lanes will be painted to guidelines as specified by the Fire Official for that particular location.

## NACOGDOCHES FIRE & RESCUE

212 East Pilar Street – P.O. Drawer 635030 • Nacogdoches, TX 75963  
(936)559-2541 • Fax (936)569-6662 • [www.ci.nacogdoches.tx.us](http://www.ci.nacogdoches.tx.us)